

SP1 - WWTP Inlet
 SP2 - Pond 2 Inlet
 SP7 - WWTP Discharge

Summary Statistics:

Parameter	DRP (mg/L)			Nitrate (mg/L)			Nitrite (mg/L)			TKN (mg/L)			TN (mg/L)			TP (mg/L)		
	SP2	SP3	SP7	SP1	SP2	SP7	SP1	SP2	SP7	SP1	SP2	SP7	SP1	SP2	SP7	SP1	SP2	SP7
Sample Location																		
Sample Count	1	14	16	14	13	16	14	13.00	16	14	13	14	14	13	16	14	13	13
Minimum	3.3	3.3	0.0	0.00	0.0	0.0	0.00	0.00	0.02	28	24	15	28	24	6.0	4.4	4.1	1.3
Mean	3.3	4.0	1.0	0.04	0.2	0.3	0.01	0.10	0.09	31	27	19	32	27	18	5.0	4.5	2.3
Median	3.3	3.9	0.8	0.02	0.1	0.2	0.01	0.02	0.05	32	27	20	32	27	20	5	4.6	1.8
90 th Percentile	3.3	4.4	1.8	0.08	0.4	0.7	0.03	0.31	0.16	34	28	21	34	28	22	5.5	4.8	3.4
Maximum	3.3	4.6	2.8	0.10	0.4	1.5	0.03	0.36	0.35	35	34	22	35	34	22	5.6	4.9	3.9
Standard Deviation	0	0.4	0.7	0.03	0.1	0.3	0.01	0.12	0.08	2	3	2	2	2	4	0.31	0.27	0.8

Parameter	Transmittance (%)			TSS (mg/L)			Escherichia coli (MPN/100mL)	pH	Ammoniacal Nitrogen (mg/L)	CBOD ₅ (mg/L)		
	SP2	SP3	SP7	SP2	SP3	SP7	SP7	SP7	SP7	SP1	SP2	SP7
Sample Location												
Sample Count	1	14	14	1	14	16	14	14	16	14	13	16
Minimum	48	53	64	11	6	0.5	1	7.3	0	26	16	1
Mean	48	56	69	11	10	16	93	7.54	16	46	23	3
Median	48	56	69	11	10	14	51	7.5	16	44	19	3
90 th Percentile	48	58	71	11	14	24	229	7.7	18	61	34	6
Maximum	48	59	74	11	17	71	330	7.8	18	83	48	6
Standard Deviation	0	2	3	0	2.9	15.5	97	0.15	4.2	14	9	2

—